



CERTIFICATE OF ANALYSIS

Customer : Avon Board of Education
Lincoln & Fifth Avenues
Avon-By-The-Sea Boro, NJ 07717

Project ID : Avon Elementary School, 505 Lincoln Avenue, Avon-By-The-Sea, NJ 07717

Matrix : Drinking Water

PAS Project ID : P22-04399

Report Date : 5/25/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04399-01	Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:02	5/24/22 13:15
P22-04399-02	GF BR IN RM004 F POE	Lead	1.07 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:08	5/24/22 13:19
P22-04399-03	GF BF BY RM004 DW	Lead	1.29 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:10	5/24/22 13:33
P22-04399-04	GF BF BY RM002 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:12	5/24/22 13:37
P22-04399-05	GF NO IN RM003 F	Lead	1.80 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:13	5/24/22 13:41
P22-04399-06	GF NOBR IN RM003 F	Lead	2.01	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:14	5/24/22 13:44
P22-04399-07	GF TL IN RM002 FP	Lead	3.91	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:16	5/24/22 13:55
P22-04399-08	1F HA BY RM106 DW A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:20	5/24/22 13:59
P22-04399-09	1F HA BY RM106 DW B	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:21	5/24/22 14:03
P22-04399-10	1F HA BY RM106 DW C	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:23	5/24/22 14:07
P22-04399-11	2F HA BY RM206 DW A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:25	5/24/22 14:10
P22-04399-12	2F HA BY RM206 DW B	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:26	5/24/22 14:14
P22-04399-13	2F HA BY RM206 DW C	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:27	5/24/22 14:18
P22-04399-14	2F KI IN RM207A FP A	Lead	8.05	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:30	5/24/22 14:21
P22-04399-15	2F KI IN RM207A FP B	Lead	1.58 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:31	5/24/22 14:25
P22-04399-16	2F KI IN RM207A FP C	Lead	2.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:33	5/24/22 14:29
P22-04399-17	2F KI IN RM207A FP D	Lead	2.74	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:35	5/24/22 14:40
P22-04399-18	2F IN RM208 DW A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:37	5/24/22 14:43
P22-04399-19	2F IN RM208 DW B	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:38	5/24/22 14:47
P22-04399-20	GF BR IN RM004 F POE FLUSH	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/23/22 06:44	5/24/22 14:50

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director